

Detail Listing of All Items Requiring Correction for 6844 11TH AVE S

Lic. or App. Number: 13345

This property was inspected by: Alan Voracek

on: 7/22/2010 at 3:00:00 P

	Date Identified	Unit/Floor	Location	Description	Action Required
<input type="checkbox"/>	7/22/2010			No Record of final inspection for building permit: RI 084359	Call for final inspection (Call 612-861-9860)
<input type="checkbox"/>	7/22/2010			No record of final inspection for electrical permit: RI 084527	Call for final inspection (Call 612-861-9860)
<input type="checkbox"/>	7/22/2010			No record of final inspection for HVAC permit: RI 085246	Call for final inspection (Call 612 861-9860)
<input type="checkbox"/>	7/22/2010		Garage	Lite fixture damaged or missing	Replace damaged or missing lite fixture.
<input type="checkbox"/>	7/22/2010	1st Floor	Bathroom	Drain clogged/slow in tub	Clean drain to flow freely.
<input type="checkbox"/>	7/22/2010	1st Floor	Bathroom	Hand held shower has potential for back siphoning	Install backflow preventer to hand held shower or remove unit and install standard shower head.
<input type="checkbox"/>	7/22/2010	2nd Floor		No Carbon Monoxide detector/or inoperable	Install carbon monoxide detector WITHIN 10' OF ALL BEDROOMS.
<input type="checkbox"/>	7/22/2010	2nd Floor	Stair	Light fixture not functioning	Verify working condition of light fixture.
<input type="checkbox"/>	7/22/2010	Basement	Laundry	Drain pipe deteriorated and/or leaking on laundry tub	Drain-Repair or replace drain pipe/trap as needed.
<input type="checkbox"/>	7/22/2010	Basement	Laundry	Tub faucet w/threads has a potential for back-siphoning.	Install backflow preventer to threads on laundry tub faucet spout or remove threads
<input type="checkbox"/>	7/22/2010	Outside	Exterior	Outside hose faucet with threads has potential of back-siphoning	Install backflow preventer to threads on faucet spout.
<input type="checkbox"/>	7/22/2010	Outside	Exterior	Dryer-exterior dryer vent damper clogged/damaged.	Dryer-repair or replace damaged exterior dryer vent damper securely & seal
<input type="checkbox"/>	7/22/2010	Outside	Yard	Brush/leaves on property	Brush/leaves on property must be removed.